

October 1, 2008

COOPER NOTIFICATION

Attn: Frank Hertzog
273 BRANCHPORT AVE
LONG BRANCH, NJ 07740

Subject: Compatibility of New Exceder Series Strobes with RSS Series strobes

Dear Frank

We have compared schematics, ASIC component specifications and your Excel spreadsheet on the similarities and differences of your new Exceder line of strobes with the currently Listed RSS series strobes. We have also compared the sync protocol used between the each of the series. Based on these facts, we have concluded that for sync compatibility, the new Exceder lines of strobes are compatible with the RSS series of strobes.

If you or your customers have any questions, please feel free to contact me.

Very Truly Yours:



D. M. Grosch
Staff Engineering Associate
Conformity Assessment Department

