

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7135-0785:127

Page 1 of 1

CATEGORY: Audible Devices

LISTEE: Wheelock Inc., 273 Branchport Ave., Long Branch NJ 07740
Contact: Deborah Piserchia (732) 433-6001 Fax (732) 222-5607

DESIGN: Multitone audible devices Models AMT-12/24, AMT4-12/24 and multitone audible/visual devices Models AMT-12-WH, AMT-24-WH, -WM, AMT4-12-WH, and AMT4-24-WH, -WM.

Unit may follow by suffixes to designate lens orientation, lettering and plate color. Models AMT, AMT4 are switchable between nominal 12 and 24 VDC with high and low output. This series can provide one of nine tone outputs. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: -12: 9 - 15.6 VDC
-24: 18 - 31 VDC

Strobe Candela:-WH: 15 cd
-WM: 117 cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to authority having jurisdiction.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as audible/visual signal devices for use with separately listed compatible control units. Suitable for outdoor when installed with weatherproof back box. Not approved for the hearing impaired applications.

These appliances can produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition. Refer to manufacturer's Installation Manual for details.

*Rev. 06-13-2006



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 18, 2009**

*Listing Expires **June 30, 2010***

Authorized By: **FRANCIS MATEO**, Program Coordinator
Fire Engineering Division