

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7125-0785:160 Page 1 of 1

**CATEGORY:** Fire Alarm Devices for the Hearing Impaired

**LISTEE:** Wheelock Inc., 273 Branchport Ave., Long Branch NJ 07740  
Contact: Deborah Piserchia (732) 433-6001 Fax (732) 222-5607

**DESIGN:** Model AMT-241575W, AMT-2475W, and \*AMT-24MCW may be followed by -NYC, followed by two alphanumeric characters indicating lettering and product color. Model AMT have a high and low output and provide a selectable setting for one tone of nine possible tones. Model number may be followed by two alpha/numeric characters indicating lens orientation, lettering and color. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Electrical: 24V = 16 - 33 VDC  
Strobe Candela: 1575W = 15cd with 75cd on axis, 75W = 75cd, wall mount only  
MCW=15cd, 30cd, 75cd or 110cd  
Flash rate : 60 flashes per minute

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to authority having jurisdiction. Models with -W are intended for wall mount only.

**MARKING:** Listee's name, model number, electrical/candela rating, and UL label.

**APPROVAL:** Listed as audible/visual signal devices suitable for the hearing impaired when used in conjunction with separately listed electrically compatible fire alarm control units. For indoor use only. For synchronization, Sync Modules SM-12/24 or SMX-12/24, Dual Sync Modules DSM-12/24 or DSMX-12/24 (CSFM Listing No. 7300-0785:132) must be used. Refer to listee's Installation Instruction Manual for details.

These appliances can produce a distinctive three pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition.

\*Rev. 06-13-06



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 18, 2009**

*Listing Expires June 30, 2010*

Authorized By: **FRANCIS MATEO**, Program Coordinator  
Fire Engineering Division