

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7320-0785:105 Page 1 of 1

**CATEGORY:** Speakers

**LISTEE:** Wheelock Inc., 273 Branchport Ave., Long Branch NJ 07740  
Contact: Deborah Piserchia (732) 433-6001 Fax (732) 222-5607

**DESIGN:** Models ET-1010, ET-1011, ET-1070, ET-1071, ET-1080, ET-1081, ET-1090 and ET-1091 series speaker or speaker/strobe. Refer to listee's data sheet for product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as a speaker for use with separately listed compatible fire alarm control units.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

\*Rev. 06-13-2006



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 18, 2009**

*Listing Expires June 30, 2010*

Authorized By: **FRANCIS MATEO**, Program Coordinator  
Fire Engineering Division