

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7135-0785:118 Page 1 of 1

CATEGORY: Audible Devices

LISTEE: Wheelock Inc., 273 Branchport Ave., Long Branch NJ 07740
Contact: Deborah Piserchia (732) 433-6001 Fax (732) 222-5607

DESIGN: Model MT-12/24, MT-115 and MT4-12/24, and MT4-115 multi-tone audible devices followed by R, W, S, or X to indicate package color.

Models MT-12, MT4-12, MT-24, MT4-24 multi-tone audible/strobe signals followed by A, B, G, R or W to indicate lens color, followed by S (15 cd), H (15 cd) or M (117 cd) to indicate strobe intensity, and other suffixes to designate orientation, lens lettering and plate color.

Models MT-115-WH and MT4-115-WH multi-tone audible/visual devices (Rated 15 cd).

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING:

Suffix -12:	*8-17.5 VDC
-24:	*16-33 VDC
-115:	120 VAC

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. Models MT series are surface mount and suitable for outdoor with Model IOB back box. Models MT4 series are flush mount and suitable for outdoor with model WBB back box.

MARKING: Listee's name, model number, electrical/candela rating and UL label.

APPROVAL: Listed as audible and audible/visual signaling devices for use with separately listed electrically compatible fire alarm control units. Not suitable for the hearing impaired application.

These appliances can produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition. Refer to manufacturer's Installation Manual for details.

*Rev. 06-13-2006



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 18, 2009**

Listing Expires June 30, 2010

Authorized By: **FRANCIS MATEO**, Program Coordinator
Fire Engineering Division