

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7320-0785:134

Page 1 of 1

CATEGORY: Speakers

LISTEE: Wheelock Inc., 273 Branchport Avenue, Long Branch, NJ 07740
Contact: * Luy Nguyen (732) 433-6005 Fax (732) 222-5607

DESIGN: Model *E60, E-70, E-90, E70, E90, ET70 and ET90 cone type speakers followed by suffix R (red), W (white), S (silver/grey) or X (special). Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 25 or 70 Vrms

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as speakers for use with separately listed electrically compatible fire alarm control units. For indoor use only.

These units do not generate a temporal pattern signal. If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

*Rev. 06-23-2006



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 11, 2007**

*Listing Expires **June 30, 2008***

Authorized By: **MIKE TANAKA, Senior Deputy State Fire Marshal**
Program Manager