

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7320-0785:164

Page 1 of 1

CATEGORY: Speakers

LISTEE: Wheelock Inc., 273 Branchport Ave., Long Branch NJ 07740
Contact: Deborah Piserchia (732) 433-6001 Fax (732) 222-5607

DESIGN: S8 Series speaker/strobes, Models S8-70/25 eight inch speaker, Models S8-24MCC and S8-24MCCH speaker/strobe. *Units are to be mounted in listed Model CBB-8 or EZ-95-8 backbox. Refer to listee's data sheet for product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as speakers and speaker/strobes for use with separately listed compatible fire alarm control units. Refer to manufacturer's Installation Manual for details.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal.

*Rev 06-13-2006



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 18, 2009**

Listing Expires June 30, 2010

Authorized By: **FRANCIS MATEO**, Program Coordinator
Fire Engineering Division