

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7320-0785:166

Page 1 of 1

CATEGORY: Speakers

LISTEE: Wheelock Inc., 273 Branchport Ave., Long Branch NJ 07740
Contact: * Luy Nguyen (732) 433-6005 Fax (732) 222-5607

DESIGN: Model E50 Speaker. May be followed by suffixes FR for red and FW for white indicating unit colors. Model can be mounted to a Model SB speaker backbox. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 25 V or 70 V (rms)

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. For indoor use only.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as speakers for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instructions Manual for details.

If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition is required, the control units must be used with appliances that can generate the temporal pattern signal

*Rev. 06-13-06



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 11, 2007**

*Listing Expires **June 30, 2008***

Authorized By: **MIKE TANAKA, Senior Deputy State Fire Marshal**
Program Manager